



# Town of Wallkill

## Water & Sewer Department

Office: (845) 342-1668

[watersewer@townofwallkill.com](mailto:watersewer@townofwallkill.com)

Tim Grogan  
Superintendent



### WATER METER INSTALLATION

Effective immediately all water meters shall be installed to the following specifications:

- I. A Ball valve shall be installed immediately after the entry of the water service pipe into the building.
- II. Where Water Pressure within a building exceeds 80 psi static, an approved water-pressure reducing valve conforming to ASSE 1003 with strainer shall be installed to reduce the pressure in the building water distribution piping to 80 psi static or less.
- III. Where Water Pressure within a building is less than 40 psi static, an approved Water Pressure Booster System must be installed to maintain a minimum of 40 psi static, but not to exceed 80 psi static.
- IV. Appropriate meter supplied by The Town of Wallkill shall be installed. Meter **must** be purchased from The Town of Wallkill Water Department.
- V. A double check valve (watts No. 7 or equal) must be installed downstream from meter.
- VI. Services over 1" will be installed with the proper backflow prevention device as per Town Code section 242-10.
- VII. A pressure relief valve set at 150 pounds must be installed downstream from check valve.
- VIII. Install expansion absorber (Amtrol ST-5, ST-12 or equal) downstream from relief valve.
- IX. Install Ball valve equal to the size of the service line downstream from expansion tank.

**Please give this sheet to the plumber.**

Water Permit

Permit Number \_\_\_\_\_ Section \_\_\_\_\_ Block \_\_\_\_\_ Lot \_\_\_\_\_

The applicant hereby applies for a permit to make water connection at the property located at \_\_\_\_\_  
\_\_\_\_\_ in the water district and agrees to comply with all applicable ordinances, local laws, rules  
and regulations.

**Property Owner's Name & Address:** \_\_\_\_\_

**Property Owner's phone# and email address:** \_\_\_\_\_

**Name, phone and email contact** for party responsible for paying the water/sewer invoices:  
\_\_\_\_\_

Contractor's Name: \_\_\_\_\_

Contractor's cell # and email address: \_\_\_\_\_

**Meter Size you are requesting:** \_\_\_\_\_

Class 1 Standard 5/8" x 3/8"

Fee \$ 226.10

Class 2 Larger than Standard

\$ call (845) 342-1668 for price

Tap in Fee

Fee \$250.00 \$

Out of District

Fee \$500.00 \$

Meter # \_\_\_\_\_

R/O # \_\_\_\_\_

\_\_\_\_\_  
Signature of Applicant

\*\*ALL WATER HOOK UPS MUST BE INSPECTED AND APPROVED BEFORE BACKFILLING\*\*

COMPLETION CERTIFICATION

I, \_\_\_\_\_, do Hereby certify that the connection of the public water

**(Owner or Contractor)**

main, pursuant to above application and permit, was completed \_\_\_\_\_ all in

(Date)

accordance with the specifications and regulations of the Town of Wallkill local Law.

Dated: \_\_\_\_\_

\_\_\_\_\_  
**Owner/Contractor**

Completion Approved:

\_\_\_\_\_  
Town of Wallkill Water Dept.

OFFICE USE ONLY

Permit is hereby granted for making public water connection in accordance with above application.

Fee \$ \_\_\_\_\_

Paid (Y/N) \_\_\_\_\_

Water Districts \_\_\_\_\_

Units \_\_\_\_\_

Date: \_\_\_\_\_

\_\_\_\_\_  
Town of Wallkill