



TOWN OF WALLKILL
PLANNING BOARD
TECHNICAL REVIEW COMMENTS

PROJECT NAME: HASBROUCK
PROJECT NUMBER: 21-49
PROJECT LOCATION: 859-901 SILVER LAKE SCOTCHTOWN ROAD/24-1-83
PREPARATION DATE: 14 APRIL 2022
MEETING DATE: 20 APRIL 2022
REPRESENTATIVE: ENGINEERING PROPERTIES
TOWN ENGINEER: MICHAEL W. WEEKS, P.E.

1. The subdivision requires creation of a Lighting District, Drainage District and Water District extension.
2. The Applicant shall identify the ownership and management of the conservation areas in accordance with the Town of Wallkill Town Code.
3. A preliminary subdivision plan is required.
4. Identify the proposed Right of Way width.
5. Provide additional information in regards to the identified proximity to buildings, archeological sites or district, which are listed or eligible for the National/State Register.
6. Provide additional information on how potential impacts to identified endangered species will be mitigated.
7. The pavement section shall conform with the Town of Wallkill Rural Street Standards; subbase course shall be 9" in depth.

NEW YORK OFFICE

33 Airport Center Drive, Suite 202, New Windsor, NY 12553
845-567-3100 | F: 845-567-3232 | mheny@mhepc.com

PENNSYLVANIA OFFICE

111 Wheatfield Drive, Suite 1, Milford, PA 18337
570-296-2765 | F: 570-296-2767 | mhepa@mhepc.com

Actions Required by the Planning Board

1. Set Public Hearing date.

Respectfully submitted,

MHE Engineering, D.P.C.

A handwritten signature in black ink that reads "Michael W. Weeks". The signature is written in a cursive style with a large initial 'M' and 'W'.

Michael W. Weeks, P.E.
Engineer for the Town

F:\1988\88-125 Town of Wallkill - NEW\21-49 Hasbrouck\Planning Board\Technical Review Comments\4-20-22 Hasbrouck 21-49.docx